

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by Sunjaybhai R. Duvut (Sr. chemist)

(Name of Officers with designation) from GWSSB, Limkheda PHED

inspected the E.M.R.S. Likhadiya, Dhampur, Dist-Dahod, Gujarat

(Name & Address of the school) on 25-06-26 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. TCW-2063/06-26 dated 29-06-26

of Taluka Laboratory, GWSSB (PHED Lab) certified that the

E.M.R.S. Likhadiya (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till IS 10500 Guidelines by the Bureau of Indian Standards (BIS) water Testing Report Validity is 6-Months of generated of Report.

Signature with Seal:

Name

Designation

Name & Address of the Office/ Department

Deputy Executive Engineer

Public Health Sanitary Sub Division

Limkheda

To

E.M.R.S. LUKHADIYA

DHAMPUR, DAHOD

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



**Taluka Laboratory,
Limkheda,**
Gujarat Water Supply &
Sewerage Board
Front of New, Court,Zulelal
Ganaral 1st Floor, Godhara
Road Limkheda-389140 Ph -
02677-229782



E mail :
limkheldalab123@gmail.com

તાલુકા પ્રયોગશાળા, લીમખેડા,
ગુ.પા.પુ.અને ગ.વ્ય.બોર્ડ,નવી ગોંડ સમી,
ગુલેલાલ જનરલ રોડ,પહેલો માળ,
ગોધરા રોડ લીમખેડા-૩૮૯૧૪૦, ગુજરાત
૦૨૬૭૭-૨૨૯૭૮૨

NABL Recognized
Laboratory
Certificate No. NABL-DWT-
01064
Valid Up to: 17-03-2028

Test Report

Name & Address of Customer:-

Principal

EMRS Lakhadiya

Dahod

Customer Reference No. :

EMRS/Lakhadiya/2063/27/P/11

Sample Submitted by :

Customer

Date of Sample Receipt :

25-06-26

Analysis Starting Date :

25-06-26

Analysis completion Date :

25-06-26

ULR No :

Discipline :

Chemical Testing, Group: Water

Test Report No: 2063/2026-27

Date of Issue :

29-06-26

Sample ID : LCW-2063/06-26

Mode of Sample :

Satisfactory

Main Source : Ground Water

Source : Tube Well

Location : In E.M.R.School Compaund

Village : Lakhadiya

Habitation : Patel Falia

Taluka : Dhanpur

District : Dahod

Latitude : ---

Longitude : ---

Kindly find herewith the Analytical Results.

Sample Type : Drinking Water

Sr. No.	Parameter	Unit	IS-10500:2012 (2nd Revision)		Reference Method :	Analytical Value
			Requirement (Acceptable Limit) Max.	Permissible Limit in the Absence of Alternate Source Max.		
1	Colour	Hazen	5	15	APHA (24th Ed.2023), Method: 2120 C	<5
2	Odour	-	Agreeable	Agreeable	IS 3025 (Part 5) - 2018 (Second Revision)	Agreeable
3	Taste	-	Agreeable	Agreeable	IS 3025 (Part 8) -2023	Agreeable
4	Turbidity	NTU	1	5	APHA (24th Ed.2023), Method: 2130 B	0.74
5	pH at 25°C	-	6.5 to 8.5	No relaxation	APHA (24th Ed.2023) Method: 4500 H ⁺ B	7.48
6	Total Dissolved Solids	mg/l	500	2000	APHA (24th Ed.2023) Method: 2540 C	406
7	Total Hardness(as CaCO ₃)	mg/l	200	600	APHA (24th Ed.2023) Method: 2340 C	260
8	Calcium (as Ca ⁺²)	mg/l	75	200	APHA (24th Ed.2023) Method: 3500 Ca ⁺² B	53
9	Magnesium (as Mg ⁺²)	mg/l	30	100	APHA (24 th Ed.2023) Method: 3500-Mg ⁺² B	31
10	Chloride (as Cl ⁻)	mg/l	250	1000	APHA (24th Ed.2023) Method: 4500-Cl ⁻ B	40
11	Sulphate (as SO ₄ ⁻²)	mg/l	200	400	APHA (24th Ed.2023) Method: 4500-SO ₄ ⁻² E	32
12	Nitrate (as NO ₃ ⁻)	mg/l	45	No relaxation	APHA (24th Ed.2023) Method: 4500-NO ₃ ⁻ B	10.97
13	Fluoride (as F ⁻)	mg/l	1.00	1.50	APHA (24th Ed.2023) Method: 4500-F ⁻ C	0.68
14	Total Alkalinity (as CaCO ₃)	mg/l	200	600	APHA (24th Ed.2023) Method: 2320 B	276

This Report is issued under the following terms & Condition :

1. This report is referring only to the tested sample and for applicable parameter.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part, and can't be used be as evidence in court of law.
4. Please refer back page for IS 10500 2012 (2nd Revision) Limits.

Issued By:

Ravat Mukeshbhai B. Lab Analyst

Name & Designation of

Authorized Signatory

O.W.No. TL/ 19 /of 2026, Dt. 02/07/2026

End of the Test Report